



Czech

# PROTOCOL

## ON THE ASSESSMENT OF PERFORMANCE OF THE PRODUCT

**Registration No. 1017 – CPR – 08.386.627**

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 laying down harmonised conditions for the marketing of construction products and repealing Council Directive 89/106/EEC, and in compliance with Commission Delegated Regulation (EU) No 568/2014, this protocol is issued for the construction product:

### Rolling grilles

**Type: AEG (AEG56, AEG56/P, AEG56m, AEG56m/P, AEG84)**

### Alutech Incorporated LLC

10 Selitskogo St., 220075 Minsk, Belarus  
Business ID No: 101452725

**Place of production: see above**

On the basis of testing, calculations, tabulated values and documentation within system 3 according to Annex V 1.4 CPR, TÜV SÜD Czech s.r.o. assessed the relevant characteristics of the product described in Annex ZA of the standard

### EN 13241-1: 2003/A1:2011

The number of pages of this Protocol inclusive the title-page: 3

Essential characteristics	Performance	Harmonised technical specification
Safe opening	Pass	EN 13241:2003/A1:2011 (4.2.8)
Release of dangerous substances	Pass	EN 13241:2003/A1:2011 (4.2.9)
Operating forces	Pass	EN 13241:2003/A1:2011 (4.3.3)
Watertightness	NPD	EN 13241:2003/A1:2011 (4.4.2)
Resistance to wind load	Class 0	EN 13241:2003/A1:2011 (4.4.3)
Thermal resistance	NPD	EN 13241:2003/A1:2011 (4.4.5, 6)
Air permeability	NPD	EN 13241:2003/A1:2011 (4.4.6)
Durability of the performance characteristics	NPD	EN 13241:2003/A1:2011 (4.4.7)

Prague, date 17.09.2015



on behalf of Notified Body 1017  
Jana Bačinová  
Head of Quality Department